



SGS-CSTC Standards Technical Services (Qingdao) Co., Ltd.



# Test Report

SGS Sample No.:

Sample Name: Calcium Sulfit

Chlorine Remove Ceramic Ball

Client Name: Zhangqiu city Longxin Corundum  
Products Co.,Ltd .

29 Oct 2020





## ATTENTIONS

1. The report would be invalid if there is no signature of prepared, checked or approved person.
2. The report would be invalid if altered.
3. Sample(s) and related information were submitted and certified by the client, SGS quoted the information with no responsibility as to the accuracy, adequacy and/or completeness.
4. Unless otherwise stated the results shown in this test report refer only to the items tested. This document cannot be used for publicity, without prior written approval of the SGS.
5. Without written approval of the laboratory shall not copy the report (except full-text copy).
6. Any question with the inspection report should be submitted to the inspection unit within 15 days from receiving the report. After the specified date any request would be refused.

Address: No.143, Zhuzhou Road, Laoshan District, Qingdao

Phone: 0532-68999281

Zip code: 266101

Fax: 0532-83884538

E-mail: [Zac.Wu@sgs.com](mailto:Zac.Wu@sgs.com)





SGS-CSTC Standards Technical Services (Qingdao) Co., Ltd.

Test Report

SGS Sample No.:

Sample name	Calcium Sulfite Chlorine Remove Ceramic Ball	Date of sample received	12 Oct 2020
Client name	Zhangqiu city Longxin Corundum Products Co.,ltd ,	Sample quantity	/
Manufacturer	/	Sample Description	solid in bag
Product Date/Batch No.	20200815	Date of test completed	29 Oct 2020

The hygienic safety test for the sample submitted by the applicant, was carried out in accordance with 'Standard for Hygienic Safety Evaluation of Equipment and Protective Materials in Drinking Water'(2001).

The standard method 'Standard examination methods for drinking water' (GB/T 5750-2006) was adopted by the test. The sample was prepared by applicant: Flush sample 30min with tap water .Immerse the sample into 100 volume exposure water and maintained in dark place for 24h± 1h at a temperature of 25± 5°C.Then the extractant water is collected and analyzed.

(Blank below)

This test report is in Chinese and maybe translated into other languages, the Chinese version shall prevail

APPROVED  
DATE:



*[Handwritten signature]*  
2020.10.29

CHECKED BY:  
DATE:

*[Handwritten signature]*

2020.10.29

PREPARED BY  
DATE:

*[Handwritten signature]*

2020.10.29





SGS-CSTC Standards Technical Services (Qingdao) Co., Ltd.

# Test Report

SGS Sample No.:

Sample Name	Calcium Sulfite Chlorine Remove Ceramic Ball	Date of sample received	12 Oct 2020
Test items	Hygienic Safety Test	Date of test completed	29 Oct 2020

## Test Result(s)

Test item(s)	Unit(s)	Test result(s)	
		Blank	Sample 002
Color (Pt-Co)	°	<5	<5
Turbidity	NTU	0.20	0.29
Odor and taste	/	No any odor and taste	No any odor and taste
Visible substance	/	None	None
pH	/	8.08	8.18
Total Dissolved Solids	mg/L	221	226
Oxygen Consumption	mg/L	0.74	0.79
Volatile Phenolic Compounds	mg/L	<0.002	<0.002
Iron (Fe)	mg/L	<0.02	<0.02
Manganese (Mn)	mg/L	<0.01	<0.01
Copper (Cu)	mg/L	<0.001	<0.001
Zinc (Zn)	mg/L	<0.02	<0.02
Cadmium (Cd)	mg/L	<0.0001	<0.0001
Arsenic (As)	mg/L	<0.0005	<0.0005
Lead (Pb)	mg/L	<0.0005	0.0008
Mercury (Hg)	mg/L	<0.0001	<0.0001
Aluminum (Al)	mg/L	<0.01	<0.01
Barium(Ba)	mg/L	<0.005	<0.005
Nickel(Ni)	mg/L	<0.001	<0.001
Antimony(Sb)	mg/L	<0.0005	<0.0005
Tin(Sn)	mg/L	<0.002	<0.002
Chromium(VI)	mg/L	<0.004	<0.004
Chloroform	mg/L	0.0002	<0.0001
Carbon Tetrachloride	mg/L	<0.0001	<0.0001

Remark: Chinese shall prevail in this report.

APPROVED BY:

DATE:



CHECKED BY:

DATE:

李敏  
2020.10.29

PREPARED BY:

DATE:

王欣  
2020.10.29



SGS-CSTC Standards Technical Services (Qingdao) Co., Ltd.

# Test Report

SGS Sample No.:

Sample photo:



\*\*\*End\*\*\*

APPROVED BY:  
DATE:



CHECKED BY:  
DATE:

李敏  
2020.10.29

PREPARED BY:  
DATE:

王欣  
2020.10.29